

# CERTIFICATION Notice

An Urgent Bulletin from CSA Group

**Wiring Devices No. 113**

**Effective Date: July 30, 2017**

**Date: August 9, 2016**

**Apply Before January 1, 2017**

Announcing: Publication of Update No.1 CSA Standard C22.2 No. 42.1-13/UL 514D Second Edition Cover Plates for Flush-Mounted Wiring Devices

Class No: 4413 02, OUTLET BOXES AND FITTINGS - Plates and Covers  
4413 82, OUTLET BOXES AND FITTINGS - Plates and Covers - Certified to US Standards

To purchase the Standard, visit us at [www.shop.csa.ca](http://www.shop.csa.ca)

## Who is affected?

Manufacturers of cover plates for flush mounted wiring devices including Extra-duty outlet box hoods.

## What do you do?

1. CSA Group Service Delivery staff will contact you to address compliance with each revision as applicable to the product designs covered in your affected Certification Reports. In addition to updates to your Certificate(s) of Compliance & Report(s), testing may be required to comply with these revisions.
2. Please respond within thirty (30) days of receiving CSA Group's "Application for CSA Certification Services" and "Quotation" communication. You must respond no later than January 1, 2017 in order to guarantee the update to your certification is completed by July 30, 2017. If testing is needed, we will inform you of the samples required.

## Approvals:

This announces the publication of Update No.1 dated March, 2016 for Standard CSA C22.2 No. 42.1-13/UL 514D Second Edition Cover Plates for Flush-Mounted Wiring Devices. This update amends the published standard and adds additional requirements that currently certified products are required to meet.

## Major Revisions:

The revisions in Update No.1 of CSA C22.2 No. 42.1-13/UL 514D, include new requirements for "Extra Heavy Duty" outlet box hoods. An outlet box hood that is intended for use with receptacles of 15 and 20 A in a wet location will now need to be marked "Extra-Duty" and meet the requirements for Extra-Duty hoods including the Vertical axis hinge stress test. Other revisions in Update No. 1 are editorial only.

For questions specific to your file or products contact your CSA Group technical staff associate.

Go to <http://www.csagroup.org/services/testing-and-certification/certified-product-listing/> and enter your Master Contract # and the class numbers associated with this Notice to determine which of your products are affected.

## For technical questions on this Certification Notice

Contact Todd Hamden  
by phone 416.747.2225, fax 416.401.6533  
or e-mail [todd.hamden@csagroup.org](mailto:todd.hamden@csagroup.org)

The standard edition or amendments announced in this Notice may be used for certification as of the date of issue of this Notice. The "Effective date" in this Notice is the date on which the current requirements, applicable to Certified products listed in the affected class numbers, expire and the standard edition or amendments announced in this Notice become the only requirements that may be used for certification.

In the event that currently certified products do not comply with the latest requirements outlined in this Notice after the "effective date", the certification of such models may be discontinued.



Visit us at [www.csagroup.org](http://www.csagroup.org) click on "Contact Us" for the online phone listing of our Offices and Partners