

Ref No: 95-001

Date: January 10, 1995

**WIRING PRODUCTS NO. 3**

To: Manufacturers of Modular Wiring Systems for Office Furniture

Subject: **Publication of Amendments to CSA Standard C22.2  
No. 203-M91, "Modular Wiring Systems for Office Furniture"**

**General**

The amendments, which were prepared by the Subcommittee on CSA Standard C22.2 No. 203-M91 and formally approved by the Technical Committee on Wiring Products, were published in August 1994 as General Instruction No. 3 and include the following:

1. **Scope**

Clause 1.2 is revised as follows:

Existing wording:

**1.2**

This Standard applies to equipment intended to be connected to supply circuits at a nominal system voltage of 120 V to ground, and a maximum rating of 20 A per circuit, for use in nonhazardous locations, in accordance with the Rules of the *Canadian Electrical Code, Part I*.

Revised wording:

**1.2**

This Standard applies to equipment intended to be connected to one or more supply circuits at a nominal system voltage of 120 V to ground, and a maximum rating of 20 A per circuit, for use in nonhazardous locations, in accordance with the Rules of the *Canadian Electrical Code, Part I*.

2. **Clause 4.5.1.8 is revised as follows:**

Existing wording:

**4.5.1.8**

A feed assembly shall be constructed such that when it is disconnected from the supply source all circuits are deenergized.



Revised wording:

**4.5.1.8**

A feed assembly for connection to one or more supply sources shall be constructed such that when it is disconnected, all circuits are deenergized. No single circuit may be powered by more than one source.

3. **Clause 5.4 is revised as follows:**

Existing wording:

**5.4**

Each feed assembly supplying power to an office furniture system shall be marked with the following or equivalent wording:

WARNING: CONNECT TO BRANCH CIRCUIT AT ONE POINT ONLY

and

AVERTISSEMENT: RACCORDER À LA DÉRIVATION, EN UN POINT SEULEMENT.

Revised wording:

**5.4**

Each feed assembly supplying power to an office furniture system shall be marked with the following or equivalent wording:

WARNING: THIS OFFICE FURNISHING SYSTEM MAY BE CONNECTED TO MORE THAN ONE SOURCE OF SUPPLY. ALL SOURCES MUST BE DISCONNECTED PRIOR TO ANY SERVICING. NO SINGLE CIRCUIT MAY BE POWERED BY MORE THAN ONE SOURCE.

and

AVERTISSEMENT: CE SYSTÈME PEUT ÊTRE RACCORDÉ À PLUS D'UNE SOURCE D'ALIMENTATION. TOUTES LES SOURCES D'ALIMENTATION DOIVENT ÊTRE COUPÉES AVANT LE DÉPANNAGE. AUCUN CIRCUIT NE DOIT ÊTRE ALIMENTÉ PAR PLUS D'UNE SOURCE.

**Effective Date:** June 1, 1995

**Direction**

- a) Customers currently holding CSA Certification are required to show evidence of compliance with the requirements of revised Clause 4.5.1.8 and also revised Clause 5.4.

Such evidence of compliance should be made available for review by CSA Field Representatives during factory follow-up visits made subsequent to the publication of this Informs and before the effective date of June 1, 1995.

- b) New applications for Certification will be required to meet the requirements of revised Clauses 4.5.1.8 and 5.4, in addition to all other applicable requirements of the Standard.
- c) From June 1, 1995, only Modular Wiring Systems for Office Furniture found in compliance with all of the applicable requirements of the Standard, including the revised Clause 4.5.1.8 and Clause 5.4 will be eligible to be marked with the CSA Monogram.

This CSA Informs is applicable to products Certified under the following CSA Product Classification:

6242 03WIRING SYSTEMS AND ACCESSORIES - Modular

### **Applications and Inquiries**

If you wish to make an application for Certification, or wish to obtain further information regarding this CSA Informs, please contact one of the CSA Offices or CSA Network Partners listed below.

#### **CSA Offices**

	<b><u>Telephone</u></b>	<b><u>Telefax</u></b>
Moncton	(506) 858-9300	(506) 858-9302
Montreal	(514) 694-8110	(514) 694-5001
Rexdale	(416) 747-4300	(416) 747-2475
Rexdale (Standards Sales)	(416) 747-4044	(416) 747-2475
Winnipeg	(204) 632-6633	(204) 632-1796
Edmonton	(403) 450-2111	(403) 461-5322
Vancouver	(604) 273-4581	(604) 273-5815
Hong Kong	(852) 664-2872	(852) 664-5033
Japan	(81) 3-3234-3553	(81) 3-3234-8678

#### **CSA Network Partners**

##### **Pacific Rim (and Far East):**

SAQAS (Australia)	(61) 2-746-4900	(61) 2-746-8460
CCIC (China)	(86) 755-200835	(86) 755-200835
HKSTC (Hong Kong)	(852) 664-2872	(852) 664-5033
BIS (India)	(91) 3310131	(91) 3314062
JQA (Japan)	(81) 3-3416-0137	(81) 3-3416-2986
A-PEX (Japan)	(81) 596-24-6717	(81) 596-24-1746
I-TEC (Japan)	(81) 45-253-1835	(81) 45-253-1869
SIRIM (Malaysia)	(60) 3-559-2601	(60) 3-550-8095
SANZ (New Zealand)	(64) 4-384-2108	(64) 4-384-3938
SISIR (Singapore)	(65) 778-7777	(65) 776-1280
KAITECH (South Korea)	(82) 2-860-1453	(82) 2-860-1465
CTS (Taiwan)	(886) 2-299-5023	(886) 2-299-5022

##### **Europe (and Middle East):**

OVE (Austria)	(43) 1-375-807	(43) 1-374-051
LCIE (France)	(33) 1-4095-6120	(33) 1-4095-6003
UTE (France)	(33) 1-4-691-1244	(33) 1-4-789-4587
N.V. KEMA (Netherlands)	(31) 85-562831	(31) 85-514922
VDE-PZI (Germany)	(49) 69 830-6436	(49) 69 830-6666
PCBC (Poland)	(48) 2227-7071	(48) 2226-6765
SII (Israel)	(972) 3-6465-147	(972) 3-6465-286
IMQ (Italy)	(39) 2-507-3220	(39) 2-507-3271
SEMKO AB (Sweden)	(46) 8-750-0350	(46) 8-750-6030
SEV (Switzerland)	(41) 1-384-9111	(41) 1-422-1426
BSI (U.K.)	(44) 908-220908	(44) 908-220671
BSI Testing (U.K.)	(44) 442-230-442	(44) 442-231-442

**North America:**

CCL (Utah)	(801) 972-6146	(801) 972-8432
PSE (California)	(714) 453-8311	(714) 453-8438
PSE (Florida)	(813) 989-2360	(813) 989-2373
PSE (New Hampshire)	(603) 886-2958	(603) 886-0987

**South America:**

BV Bureau Veritas	(55) 11-241-0733	(55) 11-531-8455
-------------------	------------------	------------------