

PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

FlowCERT Lite
With dB3 transducer and remote temperature sensor dB3 transducer with twin Pulsar sun shields using internal temperature compensation

Manufactured by:

Pulsar Process Measurement Ltd

Cardinal Building
Enigma Commercial Centre
Sandy's Road
Malvern, Worcestershire
WR14 1JJ

has been assessed by Sira Certification Service
and for the conditions stated on this certificate complies with:

MCERTS Performance Standards for Continuous Water Monitoring Equipment – Part 3 Version dated July 2018


The combined performance characteristic (U_c , the expanded uncertainty) is **0.193%** (Class1)

Certification Ranges:

0 to 3m (nominal)

Certification is awarded in respect of the conditions stated in this certificate

Project No.: 674/0363 / 80009812
Certificate No: Sira MC090155/15
Initial Certification: 03 September 2009
This Certificate issued: 17 March 2021
Renewal Date: 02 September 2024



Andrew Young
Environmental Project Engineer

MCERTS is operated on behalf of the Environment Agency by

Sira Certification Service

Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
Tel: +44 (0)1244 670 900



*The MCERTS certificate consists of this document in its entirety.
For conditions of use, please consider all the information within.
This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certificate Contents

Approved Site Application.....	2
Basis of Certification	2
Product Certified.....	2
Certified Performance	3
Description.....	5
General Notes	5

Approved Site Application

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at www.mcerts.net

The product is suitable for use, where it is appropriate, for regulated applications such as abstraction, effluent discharge, ultraviolet disinfection and industrial processing.

Basis of Certification

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

Sira Evaluation Report 6740363, dated 20 August 2009
CSA Group Evaluation Report 10/05/2016 Issue 4

Product Certified

The FlowCERT Lite measuring system consists of the following parts:

- Flow CERT Lite
- dB3 transducer
- Remote temp sensor (PT100 Class B3)

or

- Flow CERT Lite
- dB3 transducer with twin Pulsar sun shields

This certificate applies to all instruments fitted with software version 7.1.9 onwards, serial number 267230 (Flow CERT Lite) and 105160 (dB3 transducer) onwards.

Certificate No: Sira MC090155/15
This Certificate issued: 17 March 2021

Certified Performance

The instrument was evaluated for use under the following conditions:

Ambient Temperature Range: -20°C to +50°C

The instrument meets MCERTS Class 1 requirements for the combined performance characteristic as specified in Table 7 of the MCERTS performance standard. Details of individual performance characteristics are summarised below:

Results are expressed as error % of certification range, unless otherwise stated

Test	Results expressed as error % of certification range				Other results	MCERTS specification
	<0.1	<0.2	<0.5	<1.5		
Protection against unauthorised access	The unit is password protected, with a user level and a service level					Clause 3.1.2
Units of measurement	The indicating device and output are scaled in metric units					Clause 3.1.6
Indicating device	The flowmeter incorporates an indicating device, analogue and digital output signal					Clause 3.1.3
Flow computation	The flowmeter incorporates a facility for a user defined stage/discharge curve to be entered					Clause 3.1.11
Combined performance characteristic with external temperature probe	0.054					±0.2% Class 1 Table 7
Combined performance characteristic with integrated temperature probe		0.193				
Mean error	0.001					Clause 6.3.2 ±0.1% Class 1
Repeatability	0.002					Clause 6.3.2 0.05%
Resolution	0.017					Clause 3.1.15 <2mm Class 1
Supply voltage	0.014				22-28 V dc 100-110 V ac 200-240 V ac	Clause 6.3.3 0.025% Class 1
Output impedance	0.002				50-500Ω	Clause 6.3.4 0.025% Class 1
Ambient air temperature with external temperature probe	0.006				-20 to +50°C	Clause 6.3.6 0.075% Class 2
Ambient air temperature with integrated temperature probe	0.08					

Certificate No: Sira MC090155/15
This Certificate issued: 17 March 2021

Test	Results expressed as error % of certification range				Other results	MCERTS specification
	<0.1	<0.2	<0.5	<1.5		
Accuracy of computation	0.026					Clause 6.3.11 0.075% Class 2
User defined stage-discharge equation	0.004				Result not included in combined performance characteristic	Clause 6.3.12 0.025% Class 1
Warm up time	The unit stabilises after energising within 60 seconds					Clause 6.1.2 to be reported
Loss of Power for electronic flowmeters	No changes in pre-set data					Clause 6.3.1 to be reported
Relative humidity with external temperature probe	0.006				Result not included in combined performance characteristic	Clause 6.3.6 0.25% Class 3
Relative humidity with integrated temperature probe		0.15				
Direct Solar Radiation With external temperature probe	0.0312					Clause 6.3.10 1.0% Class 1
Direct Solar Radiation With integrated temperature probe		0.143				
Response time					<25s	Clause 6.3.19 <30 seconds
Error under field test conditions with external temperature probe	Error range -0.15% to +0.10% Field test error is <0.2% for 100% of readings					Clause 7.3 0.5% Class 2
Error under field test conditions with integrated temperature probe	Error range 0.00% to -3.875% Field test error is <0.5% for 93.33% of readings					
Up time					100%	Clause 7.4 >95%
Maintenance					none	Clause 7.5 to be reported

Note 1: The following tests are not applicable to the flowmeter:

6.3.5	Fluid temperature	6.3.15	Ancillary devices
6.3.7	Incident light	6.3.16	Effect of conduit material
6.3.8	Sensor location	6.3.17	Effect of conduit size
6.3.9	Presence of stray currents	6.3.18	Fill level
6.3.13	Bi-directional flow	6.3.20	Vibration
6.3.14	Flow reversal		

Certificate No: Sira MC090155/15
This Certificate issued: 17 March 2021

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Description

The Flow CERT Lite open channel controller has five volt free contacts for use as flow or level alarms, control functions, or assignable to pulse by volume or time units for remote recording or sampler operation. The controller is housed in a polycarbonate IP65 enclosure which has an isolated mA output proportional to 'flow rate', and an RS232 connection for parameter upload and downloading through a PC should it be required. Easy prompt led set up, with preset worldwide weirs and flumes configured and they offer a 32 point linearisation to suit head / flow calculations. Internally there are 2 totalisers, one non-resettable, the other being resettable in the field if needed.

Other communication options are Modbus or Profibus V0 or V1 via 485 connection and optional 192 kb flexible bulk data logging should it be required.

The non-contacting dB3 transducer uses 125 kHz pulses to measure liquid level to a depth of 3m from the transducer face. The narrow beam angle transducer is IP68 ATEX EEx m certified and can be separated by up to 1000m from the controller. If internal temperature compensation is to be used the db3 must be fitted with two Pulsar sun shields.

There is a choice of temperature monitoring – Either internal to the dB3 or an external remote temperature sensor.

The remote temperature sensor (PT100 Class B3) is to be fitted in a shaded area between the transducer face and the liquid being measured. This measures the ambient air temperature, to allow correction in the controller for 'speed of sound changes' resulting from sensed changes in air temperature.

General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule V09 for certificate No. Sira MC090155/14
2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.
4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No: Sira MC090155/15
This Certificate issued: 17 March 2021